



June 12, 2013

REVISED COPY

NORWESCO, INC.  
ANASTASIA R. O'HARA  
PO BOX 439  
ST BONIFACIUS MN 55375-0439

Re: Description: SEWAGE TANKS, POLYETHYLENE  
Manufacturer: NORWESCO, INC.  
Product Name: SEPTIC, PUMP, HOLDING OR SEPTIC/SEPTIC  
Model Number(s): 1000 BSR  
(46.25 IN. L.L., 36 IN. MAX. DEPTH OF BURY; 479 G.P.D. WHEN USED AS A SEPTIC  
TANK BASED ON A 3 YR. SERVICE INTERVAL FOR RESIDENTIAL WASTEWATER;  
TANK DIMENSIONS = 102 IN. L X 60 IN. W X 58 IN. H)  
Product File No: 20110174

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an alternate approval to s. SPS 384.25 (7) (b) and 384.25 (7) (e) 2. based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of August 2016 .

This alternate approval allows for manhole, service and maintenance openings to be a minimum of 20 inches in the least dimension.

This approval supersedes the approval issued on May 9, 2007 under product file number 20070187.

This alternate approval is contingent upon compliance with the following stipulation(s):

- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- Installation and servicing of this product must be in accordance with the manufacturer's instructions. A copy of the manufacturer's installation and servicing instructions must be given to the owner of the system.
- Before this product is installed a warning label meeting the requirement of SPS s. 384.25(8) (b), Wis. Admin. Code must be securely attached to the manhole cover.
- This product is labeled with a sticker that contains the following information: 1000 GALLON, 1000-2BSR along with other information.
- When the optional divider wall is installed and the tank is used as a double compartment septic tank (ST) /ST, there shall be a separator wall with 4 5/8-inch hole through to the second compartment. The second compartment shall allow the installation of an effluent filter. This option is not for use as a ST/PC (pump chamber).
- Additional information is included as attachment(s) to this letter; see attachment A.

Norwesco Incorporated  
June 12, 2013  
Page 2 of 2  
Product File No.: 20110174

As of May 15, 2008, a copy of a successful water tightness test report for this product must be AVAILABLE FOR INSPECTION AT THE MANUFACTURER'S PLANT prior to this product being used as a POWTS holding or treatment tank in Wisconsin.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Glen A. Jones  
Public Swimming Pool Plan / Plumbing Product Reviewer  
phone: (608) 267-5265  
fax: (608) 266-2602  
email: glen.jones@wi.gov